

**ALABAMA A&M UNIVERSITY**  
**NOTICE AND INSTRUCTIONS TO BIDDERS**

**Request for Life Safety Appliances Monitoring, Inspections, Testing  
and Maintenance**

**Addendum I**

Add:

- 1) Annual domestic and sprinkler backflow inspection: Must be scheduled during a time when the water can be turned off with the least amount of interruption to the University. The Vendor shall use of a differential gauge that will test the pressure on each side to ensure it holds to the specified differential pressure for the specific equipment being tested.
- 2) All radio/cellular equipment must be included in the bid price.
- 3) All required certificates shall be submitted to the University within one week of winning the bid.
- 4) New Proposal From (S

PROPOSAL FORM (revised 8/20/2022)

**Request for Life Safety Appliances Monitoring, Inspections, Testing and Maintenance**

1600

ALTERNATES:

BIDDER'S ALABAMA LICENSE:

CERTIFICATIONS:

---

---

Legal Name of Bidder

By (Legal Signature)

*Seal*