

Council Training Center Asbestos Abatement

Addendum 1

- 1) The interior transite roof panels cannot be removed without removing the entire roof. Does the University want this work completed within this scope of work or wait until the building is scheduled for demolition? **The removal of the interior transite panels along with the roof removal will be completed in this scope of work.**
- 2) If the roof removal is scheduled for a later date, will it be included in this bid as a Phase II with remobilization, or would it be rebid at a later date? **No it will be done in original scope of work**
- 3) Due to the discovered amount of pipe insulation, can the completion time be extended 20%? **Yes, it will be done in original scope of work**

- 9) It appears to remove the transite panels that the roof will have to be removed as well. Is the university going to be OK with the building being exposed to the elements? **Yes, the university understands the removal of the panels will expose the interior to the elements.**

End of Addendum